



QPS Evaluation Services Inc
 Testing, Certification and Field Evaluation Body
 Accredited in Canada, the USA, and Internationally

File
 LR1413

CERTIFICATE OF COMPLIANCE
 (ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to	Power Bus Way Ltd.
Address	5 Strathearn Avenue Brampton, Ontario L6T 4P1
Project Number	LR1413-1R3; Class B, permanently connected, intended for indoor and outdoor use, ambient 60°C max, with aluminum enclosure and polymeric cable support
Product	Cablebus
Model Number (Series)	XXXXXX-abcd-ZZ <ul style="list-style-type: none"> • The first 6 digits: Serial Number; • The next 4 digits is the model number ("ab": Height in inches and "cd": Width in inches; and • The last 2 digits: Run (Production) Number
Ratings	Class B, 3 phase, up to 46kV, 60Hz, ampacity varies from 600A to 7000A
Applicable Standards	CSA/ANSI C22.2 No. 273:19: Cablebus, Second Edition (November 2019)
Factory/Manufacturing Location	Same as applicant, as noted above

Statement of Compliance: The product(s) identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be in compliance with the relevant requirements of the above referenced standard(s). As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.



Issued By: Scott Airdrie

Signature:

Date: August 31, 2022