

QPS Evaluation Services Inc

Testing, Certification and Field Evaluation Body Accredited in Canada, the USA, and Internationally

> File LR1413

CERTIFICATE OF COMPLIANCE

(ISO TYPE 3 CERTIFICATION SYSTEM)

Issued to Power Bus Way Ltd.

Address 6900 Davand DriveMississauga, ON L5T 1J5, Canada

Project Number LR1413-1R5

Product Cablebus. Class B, permanently connected, intended for indoor and outdoor

use, ambient 60°C max, with aluminum enclosure (167 lb/ft) / steel enclosure

(300 lb/ft), in conjunction with polymeric cable support.

Model Number (Series) XXXXXX-abcd-ZZ

• The first 6 digits: Serial Number.,

• The next 4 digits is the model number ("ab": Height in inches can be 06, 08, 10, or 12 and "cd": Width in inches can be any number from 04 to 36, and

• The last 2 digits: Run (Production) Number.

Ratings Class B, 3 phase, up to 46kV, 60Hz, ampacity varies from 600A to 7000A

Applicable Standards CSA/ANSI C22.2 No. 273:19: Cablebus, Second Edition (November 2019)

Factory/Manufacturing Location Same as applicant, as noted above

Statement of Compliance: The product(s)/equipment identified in this Certificate and described in the Report covered under the above referenced project number have been investigated and found to be compliant with the relevant requirements of the above referenced standard(s) and versions. As such, they are eligible to bear the QPS Certification Mark shown below, in accordance with the provisions of QPS's Service Agreement.

IMPORTANT NOTE: In order to maintain integrity of the QPS Mark(s), this certification will be revoked if:

- Compliance with the above-mentioned Standard(s) including any, informed through QPS Standard Update Notice (QSD 55) issued in future – is not maintained, or
- The product/equipment is modified after certification is granted, without prior written consent from QPS.





Issued By: Andrew Saunders

andrew Danney

Signature: Date: April 26, 2024



